GOVERNMENT OF ANDHRA PRADESH
ABSTRACT

Water Resources Department – Industrial Water Supply –Renewal permission for drawl of 2600 KLD or 0.0335 TMC of water per annum from Krishna River for a period of Five (5) Years to M/s. Bhavya Cements Limited, Tangeda (V), Dachepalli (M), Guntur District (presently Palnadu District) - Accorded - Orders – Issued.

WATER RESOURCES (REFORMS) DEPARTMENT

G.O.Ms.No.17 **Dated:23.02.2024**
Read the following:-

1. Govt. Memo.No.2772/Reforms/A2/2015-1, Dt.30.09.2015 of Water Resources (Reforms) Dept.
2. G.O.Ms.No.97. WR (Reforms) Dept., dated:31.08.2018.
3. From the Engineer-in-Chief(Irrigation), WR Dept, Vijayawada Lr.No. ENC(I)/ EE/DEE1/AEE2/IWS(Bhavya Cement), dt: 24.01.2024.

****

O R D E R:

In G.O 2nd read above, the Government have accorded permission for drawl of 2600 KLD or 0.0335 TMC of water per annum from Krishna River for a period of Five (5) Years to M/s. Bhavya Cements Limited, Tangeda (V), Dachepalli (M), Guntur District (presently Palnadu District), which is going to expire on 07.03.2024.

2. In the letter 3rd read above, the Engineer-in-Chief (Irrigation), Water Resources Department based on the report of the Chief Engineer, Krishna Delta System, Vijayawada, has recommended the proposal to Government and requested to issue necessary orders for according renewal permission for drawl of 2600 KLD or 0.0335 TMC of water per annum from Krishna river to M/s. Bhavya Cements Limited, Tangeda (V), Dachepalli (M), Guntur District (presently Palnadu District for a further period of 5 years w.e.f **08-03-2024 to 07.03.2029**, subject to the following terms and conditions:

1. The requirement /allocation of 2600 KL/day 0.06 Cusecs/day or 0.0335 TMC water per year from the Krishna River during flood seasons only, keeping in view the meager water requirement.
2. The water drawn from the river should be utilized for the purpose for which permission is granted. Any misuse in this regard will entail cancellation of the permission without any notice and liable for imposition of penalty.
3. The entire cost of infrastructure to draw water shall be borne by the industry only.
4. Water meters or suitable approved measuring devices should be installed by the industry at their own cost to measure the water consumed and water measuring devices should be kept under the control of Water Resources Department and the representatives of the user shall be present at all times for taking readings.
5. **The industry should pay the water rate at the existing rates. The Industrial water royalty charges may be revised by the Government from time to time and the industry has to pay the revised rates as fixed by the Government from time to time. In case of failure to pay water rate/royalty, the permissions to draw water shall stands cancelled.**
6. No field bodhi or pipeline shall be taken through or along with Government land without approval of Government and if permission

accorded by the Government, the lease of Government land should be paid as fixed by the Government only.

7. The industry should obtain the prior concurrence of concerned Department for laying pipeline and for crossing etc.
8. The Industry should make their own arrangements for supplementation of water in their premises only.
9. The industry should make their own arrangements to dispose the treated effluents as per norms of A.P. Pollution Control Board in their premises only and should obtain prior permission if any needed from Government to dispose treated effluents in the natural sources.
10. The Water Resources Department reserves the right for cancellation of the permission without assigning any reasons thereof.
11. The Water Resources Department is no way responsible for non-supply/ Non availability of water due to any reasons in any particular water year.
12. The industry must strengthen the canal/river margin 100 Mts or as decided by the Water Resources Department, on either side of the proposed off take point to avoid slips, erosion of banks and to protect existing margins as directed by the Department.
13. The industry should lay the pipeline duly leaving not less than 1.00 Mts., from the toe of the flood bank.
14. The industry has to construct CC walls to avoid leakage at pipeline crossing.
15. The industry should follow the Revenue Board Standing Orders (B.S.O)
16. The industry shall pay security deposit at 2.50% on 5 years water charges for which permission is granted.
17. The permission accorded shall be initially for a period of 5 years. The permission shall have to be renewed well in advance before the expiry of permission.
18. The industry shall pay one year water charges as advance and any amount due to the Department before entering into agreement.
19. The industry should mark its own arrangements creating storage facilities for the requirement of water 2600 KL/day or 1.06 Cusecs/day or 0.0335 TMC water per year during the flood period.
20. The firm has to pay the water charges for the estimated quantity in advance at the start of the Financial Year (i.e.) before 10th April every year as per BSO.
21. The consumptive utilization of 2600 KL/day as required should not be exceeded under any circumstances.
22. A detailed plan showing the location, the intake arrangements, conveyance system etc., shall be furnished to the Department.
23. The industry shall abide any other condition laid down by the Government/Department from time to time.
24. The permission does not confer any riparian right of the industry.
25. Non-Adherence to any of the condition by the industry entails cancellation of the permission without any notice.
26. The quantity of water to be actually permitted for the drawl shall be as certified by the Industries Department.
27. The industry shall obtain all the necessary clearances required.
28. Water storage facility with a minimum capacity of 0.00515 TMC within the premises of the unit shall be constructed to the satisfaction of the Water Resources Department before the Industries is granted the permission to utilize the water.
29. The point of drawl of water shall be kept above the FRL/normal flood level.
30. The pump house shall be constructed at the point of drawl and Water Resources Department shall carry out regular inspections to curb any unauthorized drawl of water during the non-monsoon period.
31. The W.R.Department will be responsible for positioning appropriate and fool proof safe guards ensuring that under no circumstances the industry shall draw water during the non-flood season.

34. Willful and proven unauthorized tapping of water in non-flood season or in excess of the quantity authorized, in violation of the conditions under which the permission is granted, shall besides the cancellation of the permission granted, invite penal action, as per the law of land.
35. The firm has to obtain separate permission duly enclosing the drawings of pipe lines and lease amounts to be paid for the Government Land to be leased as per the prevailing norms.

3. After careful examination of the matter and on the recommendation of the Engineer-in-Chief (Irrigation), Water Resources Department, Government hereby accord renewal permission to M/s. Bhavya Cements Limited, Tangeda (V), Dachepalli (M), Guntur District (presently Palnadu District), for drawl of 2600 KLD or 0.0335 TMC of water per annum from Krishna River for a further period of 5 years w.e.f **08-03-2024 to 07.03.2029**, subject to the terms and conditions as mentioned at para-2 above.

4. The Engineer-in-Chief (Irrigation), Water Resources Department, Vijayawada, the Chief Engineer, Krishna Delta System, Vijayawada and the Collector & District Magistrate of Palanadu District shall take necessary action accordingly.

(BY ORDER AND IN THE NAME OF THE GOVERNOR OF ANDHRA PRADESH)

SHASHI BHUSHAN KUMAR
PRINCIPAL SECRETARY TO GOVERNMENT

To
The Engineer-in-Chief (Irrigation), Water Resources Department,
Andhra Pradesh, Vijayawada.
The Chief Engineer, Krishna Delta System, Vijayawada.
The Collector & District Magistrate, Palanadu District.
The Managing Director, A.P. Pollution Control Board, A.P, Vijayawada.
M/s Bhavya Cements Limited, Tangeda (V), Dachepalli (M), Guntur District (presently Palnadu District).

Copy to:
The P.S. to the Hon'ble Minister for Water Resources.
The P.S. to the Prl. Secretary to Government, Water Resources Department.
The P.S. to the Secretary to Government, Industries Department.
SF/SC.

//FORWARDED::BY ORDER//

SECTION OFFICER